

RESOLUTION NO. 96-128

A RESOLUTION OF THE LODI CITY COUNCIL  
AWARDING THE BID FOR THE SEVEN 12KV  
PADMOUNTED SWITCHGEAR

=====

WHEREAS, in answer to notice duly published in accordance with law and the order of this City Council sealed bids were received and publicly opened on August 28, 1996 at 11:00 a.m. for 12KV Padmounted Switchgear, as described in the specifications, therefore approved by the City Council on August 7, 1996; and

WHEREAS, said bids have been compared, checked, and tabulated and a report thereof filed with the City Manager as shown on Exhibit A attached; and

WHEREAS, four bids were received and evaluated; and although none of the bids meet specification, one bid, Trayer Engineering Corp. was dimensionally outside our specification a minor amount (4"), Trayer's bid met all other specifications and is within dimension requirements for use on our system; and

WHEREAS, it is staff's recommendation to award the bid to Trayer Engineering Corp., with options 1 and 2 as follows:

- Option 1      Changes the tank, sill and door requirements from mild steel to 304 stainless steel. It is recommended this option be accepted due to lower maintenance costs and lower life-cycle costs.
- Option 2      Alternate fuse manufacturer lowers the Trayer Switch costs for items #1 and #2.

WHEREAS, the City Manager recommends award of the contract for seven 12KV Padmounted Switchgear units, including Options 1 and 2, to Trayer Engineering Corporation of San Francisco, CA in the amount of \$129,504.90; and

NOW, THEREFORE, BE IT RESOLVED by the Lodi City Council that the award of the bid for seven 12KV Padmounted Switchgear units, including Options 1 and 2, be and the same is hereby awarded to Trayer Engineering Corporation of San Francisco, CA, in the amount of \$129,504.90; and

Dated:    September 18, 1996

=====


I hereby certify that Resolution No. 96-128 was passed and adopted by the City Council of the City of Lodi in a regular meeting held September 18, 1996, by the following vote:

AYES: COUNCIL MEMBERS - Davenport, Mann, Pennino, Sieglock  
and Warner (Mayor)

NOES: COUNCIL MEMBERS - None

ABSENT: COUNCIL MEMBERS - None

ABSTAIN: COUNCIL MEMBERS - None

  
JENNIFER M. PERRIN  
City Clerk



#### 12KV PADMOUNTED SWITCHGEAR, TYPE 9

Item No. 1, Quantity= 5 Supplier	Total Price (Tax Incl)	Option No. 1 Total Price (Tax Incl.)	Option No. 2 Total Price (Tax Incl.)	Grand Total (Tax Incl.)	Comments:
Trayer Engineering Corporation	\$86,356.00	\$8,754.69	(\$2,456.70)	<del>\$92,653.99</del>	Does not meet specifications - Exceeds Size Dim., sect. D6b
Shallbetter Bros., Inc., Alternate #1	\$80,004.38	\$12,256.56	n/a	\$92,260.94	Does not meet specifications - Exceeds Size Dim., sect. D6b
Shallbetter Bros., Inc.	\$58,858.43	\$10,855.81	n/a	\$69,714.24	Does not meet specifications - 200A compartment depth, sect. D6f - handles not in terminating comp., sect. D6
Cooper Power Systems	\$43,929.68	\$10,775.00	\$11,297.59	\$66,002.27	Does not meet specifications - Exceeds Size Dim., sect. D6b - no 200A bushing wells, sect. D3 - no Viewing Window, sect.D5

#### 12KV PADMOUNTED SWITCHGEAR, TYPE 11

Item No. 2, Quantity= 2 Supplier	Total Price (Tax Incl)	Option No. 1 Total Price (Tax Incl.)	Option No. 2 Total Price (Tax Incl.)	Grand Total (Tax Incl.)	Comments:
Trayer Engineering Corporation	\$33,571.00	\$3,771.25	(\$491.34)	<del>\$36,850.91</del>	Does not meet specifications - Exceeds Size Dim., sect. D6b
Shallbetter Bros., Inc., Alternate #1	\$33,725.75	\$4,902.63	n/a	\$38,628.38	Does not meet specifications - Exceeds Size Dim., sect. D6b
Shallbetter Bros., Inc.	\$25,278.15	\$4,342.33	n/a	\$29,620.48	Does not meet specifications - 200A compartment depth, sect. D6f - handles not in terminating comp., sect. D6
Cooper Power Systems	\$17,465.20	\$4,310.00	\$2,259.52	\$24,034.72	Does not meet specifications - Exceeds Size Dim., sect. D6b - no 200A bushing wells, sect. D3 - no Viewing Window, sect.D5